Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section

Sheet: Property ID: Lot #: File #:

Code:

SOIL/SITE EVALUATION

Owner: Jassica Strick (Applicant:
Address: 2926 US 4015
Proposed Facility: Dww H

Design Flow (Applicant)

Design Flow (Applicant)

Design Flow (Applicant)

Date Evaluated: 8-24-23
Design Flow (.1949): 480 GPD Property Size:

Property Recorded: Location of Site:

Public Individual Other ☐ Spring Water Supply: Evaluation Method: Auger Boring ☐ Cut

Pit Industrial Process **▼** Sewage Type of Wastewater: ☐ Mixed

P R O F I L E	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
1,2	3 1	0-8	LS Gr	Folispland	104R 7/2	>48"	_	_	PS.4
	2-5%	8-48	SL SOLE	Filsipland	104R 7/z ≥30"	-			Group
		1							
									1
	-								
					9. 1				
		1			- 4				
				5-1			,		
		1							
	1 1								
		1 1							

Description	Initial	Repair System	Other Factors (.1946):
	System		Site Classification (.1948):
Available Space (.1945)	~	~	Evaluated By: MR REHS
System Type(s)			Others Present:
Site LTAR	. 4	. 4	A.T.

COMMENTS: ____

LANDSCAPE POSITIONS	GROUP	TEXTURES	. <u>1955 LTAR</u>	CONSISTENCE MOIST	WET
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE	I	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY
FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE	II	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC
CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	III	SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3		SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC

STRUCTURE SG-SINGLE GRAIN M- MASSIVE CR-CRUMB GR-GRANULAR SBK-SUBANGULAR BLOCKY ABK-ANGULAR BLOCKY PL-PLATY

MINERALOGY SLIGHTLY EXPANSIVE

SIC-SILTY CLAY 0.4 - 0.1

EXPANSIVE

C-CLAY SC-SANDY CLAY

IV

