



Energy Efficiency Certificate

This certificate shall list the value covering the largest area

Builder, Permit Holder or Registered Design Professional

Print Name: _____

Signature: _____

Property Address: _____

Date: 11/3/15

518 McNeil Mill Rd.

Insulation Rating - List the value covering largest area to all that apply

Ceiling/roof:	R-
Wall:	R-
Floor:	R-
Closed Crawl Space Wall:	R-
Closed Crawl Space Floor:	R-
Slab:	R-
Basement Wall:	R-

Fenestration

U-Factor	
Solar Heat Gain Coefficient (SHGC)	

Building Air Leakage

Visually inspected according to 402.4.2.1 OR

Building Air Leakage Test Results

(Sec. 402.4.2.2)

-ACH50 [Target: 5.0 ACH50]

OR

-CFM50/SFSA [Target: 0.30]

Ducts:

Insulation (minimum R-8) R- 8

Total Duct Leakage Test Results (sect. 403.2.2)
(CFM25 Total/100SF) [Target: 5]

= 3.9%.

38

CFM25

LiveGreen Tester:

Rater/RFI ID #: 956125F

Date: 11/3/15

Phone:

(919) 453-4411

Certificate to be displayed permanently



Energy Efficiency Certificate

This certificate shall list the value covering the largest area

Builder, Permit Holder or Registered Design Professional

Print Name: Steven Eisenberg

Signature: Steven Eisenberg

Property Address:

518 McNeil Mill Rd.

Date: 11/3/15

Insulation Rating - List the value covering largest area to all that apply	R-Value
Ceiling/roof:	R-
Wall:	R-
Floor:	R-
Closed Crawl Space Wall:	R-
Closed Crawl Space Floor:	R-
Slab:	R-
Basement Wall:	R-

Fenestration

U-Factor	
Solar Heat Gain Coefficient (SHGC)	

Building Air Leakage

<input type="checkbox"/> Visually inspected according to 402.4.2.1 OR	
<input type="checkbox"/> Building Air Leakage Test Results (Sec. 402.4.2.2) -ACH50 [Target: 5.0 ACH50] OR -CFM50/SFSA [Target: 0.30]	

Ducts:

Insulation (minimum R-8)	R- 8
Total Duct Leakage Test Results (sect. 403.2.2) (CFM25 Total/100SF) [Target: 5]	=3.91. 38 CFM25

LiveGreen Tester:	Rater/RFI ID #:
<u>CB</u>	<u>9561268</u>
Date: <u>11/3/15</u>	Phone: <u>(919)453-4411</u>

Certificate to be displayed permanently