

Joe E Godwin Sr. , P.E., P.L.S.

Jason E Godwin , P.L.S.

ENOCH
ENGINEERS, P.A.
1403 NC Highway 50 South
Benson, North Carolina 27504
919.894.7765

Email: general@enochengineers.com

www.enochengineers.com

MATERIALS & TEST DIVISION

FIELD REPORT

PROJECT

| | | | |
|----------|---|-------------|-----------|
| CLIENT: | FISHER BUILD GROUP | DATE: | 11.2.23 |
| PROJECT: | RESI ADDITION FOOTING | CONTRACTOR: | D. FISHER |
| ADDRESS: | 254 OAK VALLEY FARM  | TECHNICIAN: | BH |
| LOT #: | BRES2308-0040 | | |

TEST SUMMARY

PERFORMED FOOTING PROJECTION EVALUATION OF SITE NOTED ABOVE. THE CONCRETE FOOTING IN THE 4 FOOT SECTION OF RIGHT/FRONT CORNER BY PATIO HAS BEEN DETERMINED TO ADEQUATELY SUPPORT THE CMU FOUNDATION LOAD APPLIED. NO ADDITIONAL REPAIRS OR RECOMMENDATIONS ISSUED. SOIL BEARING 2000PSF THROUGHOUT.

TESTING RESULTS

| SERVICE PERFORMED | TEST NO. | COMP % | WD PCF | DD PCF | MOISTURE % |
|-------------------|----------|--------|--------|--------|------------|
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

RETURN VISIT REQUIRED

YES

NO

TECHNICIAN:




Disclaimer:

Soils & Material inspections, testing results and on-site determinations contained in this report become void after 30 days of non-use of this report and/or following any inclement weather which causes structural soil or material deterioration. Additional testing will be required following a voided report determined by a North Carolina Building Code enforcement official or Enoch Engineers P.A. The client/contractor is responsible for notifying Enoch Engineers P.A. of any soil & material condition changes which could void this report.