Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section

Sheet: Property ID: Lot #: File #:

Other

Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Applicant: Address: 310 Phe Oak
Proposed Facility: SFD

Property Size:

Address: 360 Phe Oak
Proposed Facility: 40 Design Flow (.1949): 496 GPD
Location of Site:
Water Supply:
Evaluation Method: Auger Boring
Type of Wastewater:

Applicant:
Date Evaluated: 4//5/33
Design Flow (.1949): 496 GPD
Property Recorded:
Individual Well
Sewage Industrial Process □ Spring

☐ Cut

☐ Mixed

P R O F I L E	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
1	L.SS.	0-30	mGH/LS	VI+/13/mp/sex	_	48	-	-	12.5,
	2-5%	70-48	GYSL	VI+/ns/mp/sexx	104R 7/2 3.40	, 48	/	-	0.6
2	LSS.	0-34	w 61/LS	V Fr/nshp/sep		48		_	P. . c.
	2-5%	34-48	G/SCL	Ir/NS/MP/sap		48	/	-	0.5

Description	Initial System	Repair System	
Available Space (.1945)		V	
System Type(s)	V		
Site LTAR	0.0	0.5	

Other Factors (.1946): Site Classification (.1948): P.S. Revaluated By: Others Present: AT.

COMMENTS: ____

LANDSCAPE POSITIONS	GROUP	TEXTURES	. <u>1955 LTAR</u>	CONSISTENCE MOIST	WET
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE	I	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY
FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE	II	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC
CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	Ш	SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3		SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC

IV SIC-SILTY CLAY

0.4 - 0.1

C-CLAY

SC-SANDY CLAY

STRUCTURE
SG-SINGLE GRAIN
M- MASSIVE
CR-CRUMB
GR-GRANULAR
SBK-SUBANGULAR BLOCKY
ABK-ANGULAR BLOCKY
PL-PLATY

MINERALOGY SLIGHTLY EXPANSIVE

EXPANSIVE

