Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

	PROPERTY LOCATION: 25 Patton Ln (SR 1153)
ISSUED TO: Sandhills Real Estate	SUBDIVISIONLOT #
NEW REPAIR EXPANSION Type of Structure: 16'x76' SWMH	Site Improvements required prior to Construction Authorization Issuance:
Proposed Wastewater System Type: 25% reduction	
Projected Daily Flow: 360 GPD	
Number of bedrooms: 3 Number of Occupants: 6	max
Basement Yes No	
Pump Required: Yes No May be required based on final le	ocation and elevations of facilities
Type of Water Supply: Community Public Well Distan	ce from wellfeet Permit valid for: 🗵 Five years
Permit conditions:	No expiration
11 1 0 - 45	Date: 10-10-23 SEE ATTACHED SITE SKETCH
Authorized State Agent:	r permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This
	Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of
the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.	•
Constr	uction Authorization
	uired for Building Permit)
	1958, and 1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance
with the attached system layout.	
ISSUED TO: Sandhills Real Estate	PROPERTY LOCATION: 25 Patton Ln (SR 1153)
1330ED 10. Carramino recar Estato	SUBDIVISION LOT #
Facility Type: 16'x76' SWMH	Expansion Repair
Basement? Yes No Basement Fixtures? Yes	⊠ No
	(Initial) Wastewater Flow: 360 GPD
71	(IIIIIai) Wastewater Flow. 300
(See note below, if applicable □) 25% reduction	(Possiv)
50 F6- 70 F6	(Repair)
Installation Requirements/Conditions Number of trend	1925 Page 1921 P
	each trench 65feet Trench Spacing: 9 Feet on Center
0	e installed on contour at a Soil Cover: 6inches
	Depth of: 18-30 inches (Maximum soil cover shall not exceed
(Trench bottoms	shall be level to +/-1/4" 36" above the trench bottom)
in all directions)	
Pump Requirements:ft. TDH vsGPM	inches below pipe
	Aggregate Depth: inches above pipe
Conditions:	inches total
WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM A	NY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD ARE	
**If applicable: I understand the system type specified is different from	the type specified on the application. I accept the specifications of this permit.
Owner/Legal Representative Signature:	Date:
	changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This
Construction Authorization is subject to compliance with the provisions of the Laws and Rules for	Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH
m/l	2 - 40 40 60
Authorized State Agent:	Date: 10-10-23
Const	ruction Authorization Expiration Date: 10-10-28

Harnett County Department of Public Health Site Sketch

Property Location: 25 Pat	ton Ln (SR 1153)	C. I. II. J. J.	1 - 4 #	_
Issued To: Sandhills Real E	state	_ Subdivision	Lot #	
Authorized State Agent:	Mah	DEHT ZOC'	Date: 10-10-23	
coo! Red >	(25 parson Ln) 750' 16'x76 3Br 5WMH 10' 125' 125' 125' 125' 126' 12		(37 Patron (n)	200
	C POT	Ton In		

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.