



# Permit Inspections

## Harnett County

**Permit Number: BRES2309-0011**

Description: **16x23 Sunroom**

Applied: **9/8/2023**

Approved: **11/13/2023**

Site Address: **485 TYLERSTONE DR**

Issued: **11/14/2023**

Finalized: **4/8/2024**

City, State Zip Code: **FUQUAY-VARINA, NC 27526**

Status: **FINALED**

Applicant: **RODAS CRONSTRUCTION**

Parent Permit:

Owner: **MILLER LARRY**

Parent Project:

Contractor: **RODAS CRONSTRUCTION**

Details:

### LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			FOUNDATION	Justin Ryan McLeod		
Notes:						
			MONO SLAB	Justin Ryan McLeod		
Notes:						
			OPEN FLOOR	Justin Ryan McLeod		
Notes:						
			SLAB	Justin Ryan McLeod		
Notes:						
			FOOTING	Justin Ryan McLeod		
Notes:						
	1/30/2024	1/30/2024	FOOTING	Justin Ryan McLeod	DISAPPROVED	
Notes: Missing footings where old deck band was . not per engineers stamped plan						
	1/31/2024	1/31/2024	FOOTING	Daniel L Floyd	APPROVED	
Notes:						
	2/12/2024	2/12/2024	ROUGH IN	Daniel L Floyd	DISAPPROVED	
Notes: Not ready, needs all exterior doors and windows installed, needs fire stop at all penetration through the top and bottom plate, need plans onsite, will need more king studs on openings according to the 2018 NCRBC R602.7.5						





# Permit Inspections Harnett County

	3/14/2024	3/14/2024	ROUGH IN REINSPECT	Justin Ryan McLeod	DISAPPROVED	
Notes: Add king stud beside door to make 2 kings, collar ties per plan installed per code ok to insulate						
	3/19/2024	3/19/2024	ROUGH IN REINSPECT	Brad Sutton	APPROVED	
Notes:						
	3/19/2024	3/19/2024	INSULATION	Brad Sutton	APPROVED	
Notes:						
	4/8/2024	4/8/2024	FINAL**	Justin Ryan McLeod	APPROVED	
Notes:						

