APPENDIX G

DESIGN PROFESSIONAL INSPECTION FORM

RECORD OF THE INSPECTION OF A **COMPONENT OR ELEMENT** BY A NC LICENSED ARCHITECT OR ENGINEER

Project Information:

Residential Single-Family Project: (Y) N	Commercial Project: Y N	
Code Enforcement Project No:	Permit No:	
Project Name:	Owner: Reuben Meija	
Project Address: 75 Currie Drive -Spring Lake, NC	Suite No:	
Date Inspected: 06.06.24	Contractor Name:	
Component Inspected: Crawlspace Foundation		

Responsible Licensed NC Architect or NC Engineer

Name:	Jerome Rufaro Redmond, PE	
Firm Name:		
Phone Numbers:	Office: Mobile: 910.915.6529	
Email Address:	Jrednc5@yahoo.com	
Mailing Address:	1019 Hwy 17 South Ste. North Myrtle Beach, SC 29582	

A PPLICABLE	CODE:
--------------------	-------

2018 NCRC

2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code

Describe Element/Component/Type of Inspection: *

The 2x8@16" floor joists with double 2x10 girders supported by piers sufficient. The pier construction, footing and spacing meet the requirements the NCRC and Section 3.7 of the North Carolina Regulations for Manufactured Homes and the strap bracing installed adequately meets the anchorage requirements of section 3.9.

*(subgrade form/letter may also be required)

Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per G.S. 160D-11-6 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced

code. Attach any additional documents if needed.

Licensed Architect or Engineer

Inspection Department disclaimer:

Upon the receipt of a signed written document as required under subsection (a) of G.S. 160D-11-1, Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.