

September 28, 2023

Wayne Barton
20 Clyde Land
Cameron, NC 28326

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547

fax: 910-893-9371

RE: Existing Tank Application #BRES2309-0036

To whom it may concern,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover outlet lid on septic tank and break seal on lid. (\$25.00 *fee incurred*)

___ 2. Have system pumped out

___ 3. Replace Sanitary Tee with Filter

X 4. **Other – The proposed location of your swimming pool will be on top of or closer than 15 foot from your septic system. Your pool can not go in this location.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne REHS
Environmental Health Program Specialist
Harnett County Department of Public Health

MO/KH
Copy - Central Permitting