

Howerton Services, PLLC
License # P-1716
3513 Cathedral Bell Road
Raleigh, NC 27614
(919) 270-3460

February 20, 2024

Subject: 2680 Peach Farm Road
Lillington, NC 27546
Plan Revision Letter
Harnett County Permit #: BRES2310-0001

Based on the request of the Contractor, 1 item on the plans will be revised. My assessment and recommendations are as follows:

- The plans call for ½” sheetrock on the interior of the exterior Garage walls. The ½” sheetrock is not required on the interior of the exterior Garage walls. The ½” sheetrock is only required on the walls and ceiling of the bathroom inside the Garage. This modification is acceptable.

The plan modification noted above meets all the requirements of the 2018 North Carolina Building Code for Residences.

