



Permit Reviews Harnett County

Permit Number: BRES2310-0012

Description: **25x29.1 attached garage w/ 1 BDR- 1 bath apartment upstairs**

Applied: **10/5/2023**

Approved:

Site Address: **126 MASON HILL LN**

Issued:

Finalized:

City, State Zip Code: **LILLINGTON, NC 27546**

Status: **RECEIVED**

Applicant: **CUEVAS DANIEL D ROBLES**

Parent Permit:

Owner: **CUEVAS DANIEL D ROBLES**

Parent Project:

Contractor: **<NONE>**

Details:

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: 2ND PLAN REVIEW						
7/5/2024	7/19/2024	7/19/2024	ENVIRONMENTAL	MARK OSBORNE	APPROVED	
Notes: Permit to be drawn Pool will have to be removed as it sits on top of drain lines						
Review Group: AUTO						
10/5/2023		10/6/2023	CENTRAL PERMITTING INTAKE	CP Bucket		
Notes:						
6/14/2024	7/3/2024	6/28/2024	ENVIRONMENTAL	MARK OSBORNE	UNDER REVIEW	
Notes: uncover septic tank and move garage 5 foot from tank						
6/14/2024	6/18/2024	6/19/2024	RESIDENTIAL BUILDING	Brad Sutton	DISAPPROVED	
Notes: 1. Need all truss layouts from truss suppliers as well as LVL calc sheets 2. Garage cannot open into existing bedroom, or have a door, or any other communication with a sleeping area.						
6/18/2024			RESIDENTIAL BUILDING	Building Bucket		
Notes:						

