

# OPERATIONS PERMIT

Name: (owner) BENNIE H Godwin  New Installation  Septic Tank  
 Property Location: SR# 1769  Repairs  Nitrification Line  
 Subdivision \_\_\_\_\_ Lot # \_\_\_\_\_  
 TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
 Contractor: Bennie Godwin Registration # \_\_\_\_\_

Basement with Plumbing:  Garage:   
 Water Supply:  Well  Public  Community  
 Distance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other \_\_\_\_\_

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons


Subsurface No. of exact length width of depth of  
 Drainage Field ditches 2 of each ditch 150 ft. ditches 3 ft. ditches 18-20 in.

French Drain: - Linear feet

Date: 8-4-98

PERMIT NO. 11788

Inspected by: James C. Marshall EHS  
Environmental Health Specialist



# HARNETT COUNTY HEALTH DEPARTMENT IMPROVEMENT PERMIT

No 11788

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Bennie H. Gudwin  New Installation  Septic Tank  
 Property Location: SR# 1769  Repairs  Nitrification Line

Subdivision \_\_\_\_\_ Lot # \_\_\_\_\_

Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 3 Lot Size: 1+ acre 23.39 acres

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other \_\_\_\_\_

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field No. of 3 exact length 100 width of \_\_\_\_\_ depth of \_\_\_\_\_  
 Ditches 2 of each ditch 150 ft. ditches 3 ft. ditches 18-20 in.


French Drain Required: \_\_\_\_\_ Linear feet

Date: 3-26-97


\* This permit is subject to revocation if site plans or intended use change.

Signed: James C. Markham D.C.S.  
 Environmental Health Specialist

**VOID AFTER 6 YEARS**



- \* Maintain all setbacks
- \* Keep Plumbing High to Allow for tanks to be placed shallow.



- \* Keep Lateral's on contour As much as possible!