

Joe E Godwin Sr. , P.E., P.L.S.

Jason E Godwin , P.L.S.

ENOCH ENGINEERS, P.A.

1403 NC Highway 50 South
Benson, North Carolina 27504
919.894.7765

Email: general@enochengineers.com

www.enochengineers.com

MATERIALS & TEST DIVISION

FIELD REPORT

PROJECT

CLIENT:	GAMMON CONST	DATE:	4.3.25
PROJECT:	RESI STEM WALL FILL MA	CONTRACTOR:	D. GAMMON
ADDRESS:	161 ROLLING ACRES LN	TECHNICIAN:	BLH
LOT #:	COATS NC		

TEST SUMMARY

PERFORMED NDT ON STEM WALL BACKFILL AT SITE NOTED ABOVE.
SOILS CONFIRMED A COMPACTION GREATER THAN OR EQUAL TO 95% OF THE
TARGET DENSITY OF 108PCF.

TESTING RESULTS

SERVICE PERFORMED	TEST NO.	COMP %	WD PCF	DD PCF	MOISTURE %
NDT	1	100	125.6	111.8	12.0

RETURN VISIT REQUIRED

YES

☐

NO

☒

TECHNICIAN:

BLH

Disclaimer:

Soils & Material inspections, testing results and on-site determinations contained in this report become void after 30 days of non-use of this report and/or following any inclement weather which causes structural soil or material deterioration. Additional testing will be required following a voided report determined by a North Carolina Building Code enforcement official or Enoch Engineers P.A. The client/contractor is responsible for notifying Enoch Engineers P.A. of any soil & material condition changes which could void this report.