



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

5/22/2024

SUBJECT: BRES2311-0006
BUILDING RESIDENTIAL

To: PRESTIGE POOLS

Here are the results of all Inspections located at **1601 ROGERS RD:**

Inspection Type: BONDING
Scheduled Date/Time: 3/6/2024
Completed Date/Time: 3/6/2024
Inspector: Justin Ryan McLeod
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 3/5/2024 9:58 AM PRESTIGE POOLS
Pigtail on back of light niche, grounding wire and potting compound inside of light niche, conduit.
Contact Name: PRESTIGE POOLS
Site Address: 1601 ROGERS RD
Phone: 9197203455
e-Mail: sheila@prestigepoolsnc.com

Disapproved due to This being a partial bonding inspection, observed light bonded and conduit.
Ok to proceed,

Inspection Type: BONDING
Scheduled Date/Time: 3/11/2024
Completed Date/Time: 3/11/2024
Inspector: Daniel L Floyd
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 3/8/2024 10:51 AM PRESTIGE POOLS
Bonding ring inspection with water bond in the deep end skimmer
Contact Name: PRESTIGE POOLS
Site Address: 1601 ROGERS RD
Phone: 9197203455
e-Mail: sheila@prestigepoolsnc.com

Inspector JRM changed the inspection assignment from JRM to DLF
Missing a bonding point see pictures attached



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: BONDING
Scheduled Date/Time: 3/14/2024
Completed Date/Time: 3/14/2024
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 3/13/2024 12:32 PM PRESTIGE POOLS
Bonding ring inspection with water bond in the deep end skimmer
Contact Name: PRESTIGE POOLS
Site Address: 1601 ROGERS RD
Phone: 9197203455
e-Mail: sheila@prestigepoolsnc.com

Inspection Type: ELECTRICAL UNDERGROUND
Scheduled Date/Time: 4/12/2024
Completed Date/Time: 4/12/2024
Inspector: Daniel L Floyd
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 4/11/2024 11:47 AM PRESTIGE POOLS
Inspection of wire mesh bonding
Contact Name: PRESTIGE POOLS
Site Address: 1601 ROGERS RD
Phone: 9197203455
e-Mail: sheila@prestigepoolsnc.com

Inspector JRM changed the inspection assignment from JRM to DLF

Inspection Type: ZONING
Scheduled Date/Time: 5/21/2024
Completed Date/Time: 5/21/2024 12:00 PM
Inspector: Kyle Holder
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 5/20/2024 2:46 PM PRESTIGE POOLS
Contact Name: PRESTIGE POOLS
Site Address: 1601 ROGERS RD
Phone: 9197203455
e-Mail: sheila@prestigepoolsnc.com



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL**
Scheduled Date/Time: 5/21/2024
Completed Date/Time: 5/21/2024
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 5/20/2024 2:46 PM PRESTIGE POOLS

Contact Name: PRESTIGE POOLS
Site Address: 1601 ROGERS RD
Phone: 9197203455
e-Mail: sheila@prestigepoolsnc.com