

Joe E Godwin Sr. , P.E., P.L.S.

Jason E Godwin , P.L.S.

**E**NOCH  
ENGINEERS, P.A.  
1403 NC Highway 50 South  
Benson, North Carolina 27504  
919.894.7765

Email: [general@enochengineers.com](mailto:general@enochengineers.com)

[www.enochengineers.com](http://www.enochengineers.com)

## MATERIALS & TEST DIVISION

### FIELD REPORT

#### PROJECT

CLIENT:	JEFFERY HARGROVE	DATE:	6.11.24
PROJECT:	RESI PORCH SOIL FILL	CONTRACTOR:	J. HARGROVE
ADDRESS:	419 DUNBAR DR	TECHNICIAN:	BH
LOT #:	LILLINGTON NC		

#### TEST SUMMARY

PERFORMED NDT ON PORCH FILL MATERIAL AT SITE NOTED ABOVE  
 USING A TARGET DENSITY OF 108PCF.  
 SOILS CONFIRMED A COMPACTION GREATER THAN OR EQUAL TO 95%.

FRONT AND REAR PORCH FILL TESTED


#### TESTING RESULTS

SERVICE PERFORMED	TEST NO.	COMP %	WD PCF	DD PCF	MOISTURE %
NDT	F.POR <sub>H</sub>	98.24	106.1	109.6	3.3
NDT	R.POR <sub>H</sub>	98.77	106.7	110.1	3.4

#### RETURN VISIT REQUIRED

YES   
 NO

TECHNICIAN:

Disclaimer:

Soils & Material inspections, testing results and on-site determinations contained in this report become void after 30 days of non-use of this report and/or following any inclement weather which causes structural soil or material deterioration. Additional testing will be required following a voided report determined by a North Carolina Building Code enforcement official or Enoch Engineers P.A. The client/contractor is responsible for notifying Enoch Engineers P.A. of any soil & material condition changes which could void this report.