

Harnett County Department of Public Health Improvement Permit

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: 556 Hilliard Rd, Fuquay-Varina, NC, 27526
 SUBDIVISION _____ LOT # 5B

ISSUED TO: David Pegram
 NEW REPAIR EXPANSION

Type of Structure: EX. SFD
 Proposed Wastewater System Type: 25% Reduction System
 Projected Daily Flow: 480 GPD
 Number of bedrooms: 4 Number of Occupants: 8 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet
 Permit valid for: Five years No expiration
 Permit conditions: _____

Authorized State Agent: James E. Manhart JR BEHS Date: 1-8-24 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization (Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: David Pegram PROPERTY LOCATION: 556 Hilliard Rd, Fuquay-Varina, NC, 27526
 SUBDIVISION _____ LOT # 5B

Facility Type: EX. SFD New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System**: 25% Reduction System (Initial) Wastewater Flow: 480 GPD
 (See note below, if applicable 50% Reduction System (Repair))

Installation Requirements/Conditions
 Septic Tank Size Existing gallons
 Pump Tank Size _____ gallons
 Number of trenches 3
 Exact length of each trench 34 feet
 Trenches shall be installed on contour at a
 Maximum Trench Depth of: 20 inches
 (Trench bottoms shall be level to +1-1/4" in all directions)
 Trench Spacing: 9 Feet on Center
 Soil Cover: 6 inches
 (Maximum soil cover shall not exceed 36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs. _____ GPM _____ inches below pipe
 Aggregate Depth: _____ inches above pipe
 Conditions: Add 34' to each Existing Line of current 25% Reduction System _____ inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

****If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.**

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH


Authorized State Agent: James E. Manhart JR BEHS Date: 1-8-24
 Construction Authorization Expiration Date: 1-8-29

Application # Bres 2312-0106

Harnett County Department of Public Health Site Sketch

Property Location: 556 Hilliard Rd, Fuquay-Varina, NC, 27326, SR, 1456 Hilliard Rd
Issued To: David Pegram Subdivision _____ Lot # 5B

Authorized State Agent: James E. Mankard ~~IA~~ IBHS Date: 1-8-24



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.