

November 21<sup>st</sup>, 2024

Rosa Moreno  
1259 Lafayette Rd  
Fuquay Varina, NC 27526

**RE: Existing Tank Application #BRES2312-0134**

To whom it may concern

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank fully and break seal. (\$25.00 fee incurred).
- 2. Have system pumped out
- 3. Need site plan
- 4. Other – Single Wide is still in same spot above gravity septic system, on top of septic drain lines. Pictures were taken. Original Mobile Home was positioned vertical from front of lot and closer to front. Unpermitted SW is currently onsite and placed horizontal and pushed back from property line. D-Box is damaged and filter is missing in tank.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7525 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz, R.E.H.S.  
Environmental Health Specialist  
Harnett County Department of Public Health

RL/kh  
Copy - Central Permitting