
## Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit
PROPERTY LOCATION: 336 Yorkshire Drive
ISSUED TO: Melissa Braun DRANN SUBDIVISION
NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance:
Type of Structure: Modular (76'x38') SFD (64'×48)
Proposed Wastewater System Type: 25% Reduction System Projected Daily Flow: 360 GPD
Projected Daily Flow: 360 GPD  Number of bedrooms: 3 Number of Occupants: 6 max
Basement Tyes X No
Pump Required: Yes No May be required based on final location and elevations of facilities
Type of Water Supply: Community Public Well Distance from wellfeet Permit valid for: Five years
Permit conditions: No expiration
Hel He
ACALL - DIZIOA CEL ATACHER CHE CHECH
Authorized State Agent:: Date: 2/7/24 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The appropriate has been been appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The appropriate permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of
the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. REVISED 9/16/23
751176D 1/16/97
Construction Authorization
(Required for Building Permit)
The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance
with the attached system layout.
Read to the second seco
ISSUED TO: Melissa Braun DRANN PROPERTY LOCATION: 336 Yorkshire Drive
Tacility Type: Mead of the Company o
Basement? Yes No Basement Fixtures? Yes No
Type of Wastewater System** 25% Reduction System (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable )
Subsurface Drip (Repair)
Installation Requirements/Conditions Number of trenches 1
Septic Tank Size 1000 gallons Exact length of each trench 300 feet Trench Spacing: 9 Feet on Center
Pump Tank Sizegallons Trenches shall be installed on contour at a Soil Cover: 6inches
Maximum Trench Depth of: 18-12inches (Maximum soil cover shall not exceed
(Trench bottoms shall be level to +/-1/4" 36" above the trench bottom)
in all directions)
Pump Requirements:ft. TDH vsGPMinches below pipe
Aggregate Depth: inches above pipe
Conditions: See site sketch and LSS design sheet for all specifications andinches total
conditions.
WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.
**If applicable: 1 understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
Owner/Legal Representative Signature: Date:
This Construction Authorization is subject to revocation of the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This  Construction Authorization is subject to compliance with the provisions of the laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.  SEE ATTACHED SITE SKETCH
Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.
Authorized State Agent: Date: 2/7/24
Authorized State Agent: Date: 2/7/24
Authorized State Agent: Date: 217/24 Date: 217/29

REVISED 3/16/24



AL 3

TO INSTALLATION ANY QUESTIONS.

\* CURSAIN DRAIN

2.5 DEER

160,00

