

A Groundworks' Company

## Scope of Work for: 93 W Erwin St Coats NC 27521

## The following will be performed as a crawlspace encapsulation project:

- \*\*CrawlSeal System to include the following:
- -20 ml Vapor Barrier installed wall to wall with 100% floor coverage. All sections of liner will be overlapped a minimum of 1' and will be seamed together, attached with Christmas Tree fasteners, and caulked.
- -Install WallSeal on basement walls to help prevent water vapor and moisture intrusion as well as direct wall leakage to the waterproofing system. (12 ml Vapor Barrier on Walls)
- -Wrap all existing CMU/Brick Piers 20 ml Vapor Barrier. Contractor will leave a termite inspection gap at the top of each pier. The liner will be fastened to the pier and the top edge of the liner will be sealed with caulking.
- -All Vents will be sealed from inside the crawl space with R-10 Rigid 2" Foam Sheathing.
- \*\*Existing R-19 insulation will remain in the floor system.
- \*\*AprilAire E100 Dehumidifier install unit specifications on page 2
- \*\*Electrical Installation of new dedicated 120vac/20amp electrical circuit/s and electrical outlet/s (WP-GFCI) to supply sump pump and /or dehumidifier in crawl space (basement).

  Davis Dunlap Electrical LLC

  210 Timberland Dr

  Angier NC 27501

  919-669-0768

davisdunlapelectric@yahoo.com

License #27056-L



A Groundworks' Company

| SPECIFICATIONS                         |                                  |                        |
|--|----------------------------------|------------------------|
| Capacity                               |                                  | 300000                 |
|  | @ 80°F/60% RH                    | 100 ppd                |
|  | @ 73°F/60% RH                    | 85 ppd                 |
| Energy Factor                          |                                  |                        |
|  | @ 80°F/60% RH                    | 2.6 L/kW-h             |
|  | @ 73°F/60% RH                    | 2.35 L/kW-h            |
| Airflow @ varyin<br>(external static p | g E.S.P.<br>pressure - dry coil) |                        |
|  | 0.0" w.c.                        | 280 CFM                |
|  | 0.2" w.c.                        | 245 CFM                |
|  | 0.4" w.c.                        | 210 CFM                |
| Voltage, phase, frequency              |                                  | 120VAC, 1 phase, 60 Hz |
| Current draw <sup>(1)</sup>            |                                  | 6.9 Amps               |
| Noise                                  |                                  | 55 dBA ducted          |
|  |                                  | Width: 14"             |
| Dimensions:<br>(cabinet only)(2)       |                                  | Height: 15"            |
| (cabillet only)                        |                                  | Length: 26"            |
| Unit Weight                            |                                  | 64 lbs.                |
| Shipping Weight                        | t                                | 82 lbs.                |
| Inlet air operatir                     | g conditions during              |                        |
| -Dehumidification:                     |                                  | 50°F-104°F, 40°F       |
|  |                                  | dew point min.         |
| -Ventilation:                          |                                  | 40°F-140°F, 0%-99% RH  |
|  |                                  | (non-condensing)       |

<sup>&</sup>lt;sup>(i)</sup>Rated capacity, energy factor and current draw measured at 80°F/60% RH inlet air at 0.0 ESP.
<sup>(ii)</sup>Height does not include adjustable feet. The width excludes the filter doors and length excludes the duct collars.

THBS to install full encap with dehumidifier

Crawl is 3' tall at entrance and 2' tall lowest area. Some plumbing pipes half buried and some low flex ducts. THBS to have electrical installed.

93 West Erwin St. Coats 27521



