

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) K. Jarrott Corp New Installation Septic Tank
 Property Location: SR# HU7 24 Repairs Nitrification Line

Subdivision Heritage Village Lot # E-60
 Tax ID# _____ Quadrant # _____
 Number of Bedrooms Proposed: 3 Lot Size: 47,687 sq ft
 Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: _____ ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other Pump to Conventional
 Size of tank: ^{5,299 gal} Septic Tank: 1000 gallons Pump Tank: 1000 gallons
 Subsurface Drainage Field No. of ditches 2 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18 in.
 French Drain required: _____ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 9-21-95
 Signed: J. W. ARS
 Environmental Health Specialist

VOID AFTER 5 YEARS

