



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

10/16/2025

SUBJECT: **BRES2401-0062**
BUILDING RESIDENTIAL

To: Elite Pools Spas & Hardscapes

Here are the results of all Inspections located at **1022 JOE COLLINS RD:**

Inspection Type: ELECTRICAL UNDERGROUND
Scheduled Date/Time: 2/23/2024
Completed Date/Time: 2/23/2024
Inspector: John B Kokoszka
Result: APPROVED
Remarks:
Notes: Looked at the grounding wire

Inspection Type: BONDING
Scheduled Date/Time: 2/29/2024
Completed Date/Time: 2/29/2024
Inspector: John B Kokoszka
Result: APPROVED
Remarks:
Notes:

Inspection Type: ZONING
Scheduled Date/Time: 4/12/2024
Completed Date/Time: 4/12/2024 12:30 PM
Inspector: Kyle Holder
Result: APPROVED
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time: 4/23/2024
Completed Date/Time: 4/23/2024
Inspector: John B Kokoszka
Result: DISAPPROVED
Remarks:
Notes: Missing door alarm UL2017Missing thermal pool cover



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL**
Scheduled Date/Time: 5/6/2024
Completed Date/Time: 5/6/2024
Inspector: Daniel L Floyd
Result: APPROVED
Remarks:
Notes: