



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

3/12/2024

**SUBJECT: BRES2401-0088**  
**BUILDING RESIDENTIAL**

To: WILKINS DENA

Here are the results of all Inspections located at **645 MILTON WELCH RD:**

Inspection Type: MFH FINAL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks:  
Notes:

Inspection Type: SEWER CONNECTION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks:  
Notes:

Inspection Type: WATER CONNECTION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks:  
Notes:

Inspection Type: ZONING  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Planning Bucket  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: MH FOUND/MARRIAGE WALL  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks:  
Notes:

Inspection Type: FOOTING  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks:  
Notes:

Inspection Type: ADDRESS  
Scheduled Date/Time: 3/1/2024  
Completed Date/Time: 3/1/2024  
Inspector: GIS Bucket  
Result: APPROVED  
Remarks:  
Notes: 645 MILTON WELCH RD SANFORD 27332.

Inspection Type: MH FOUND/MARRIAGE WALL  
Scheduled Date/Time: 3/11/2024  
Completed Date/Time: 3/11/2024  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks:  
Notes: Need Sewer test. Missing dryer vent. Water heater blow off and condensate drain piping.

Inspection Type: FOOTING  
Scheduled Date/Time: 3/11/2024  
Completed Date/Time: 3/11/2024  
Inspector: Steven Gazlay  
Result: CANCELLED  
Remarks:  
Notes: Not needed (abs footings).

