Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section

Sheet: Property ID: Lot #: File #: Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Cadle Haves			
Owner: Codic Hayas Address: 6/13 cool springs ad	Date Evaluated:		
Proposed Facility: SFD	Design Flow (.1949): 480 GPD	Property Size:	
Location of Site:	Property Recorded:		
Water Supply: ☐ Public	c Individual Well	☐ Spring	Other
Evaluation Method: Auger Boring	☐ Pit ☐ Cut		
Type of Wastewater: Sewa	ige Industrial Process	☐ Mixed	

L E	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY		OTHER PROFILE FACTORS					
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR	R
l	L	0-4	LS	Fr/MP NX		>48"	_	_	5	3
	L 2-52	4-48	SCI	Filsop SXP	≥28"					
				Ÿ.				t.		
2	2-5%	0-4	15	Fol NSP NAP	10y261,	>48"		_	5.	3
	7-5%	4-48	Sci	Filsop SXP	≥30"					
3	,							_		-
)	2-52	0-4	LS	fr/NSP NXP	10426/1	>48.			5.	2
	154	4-418	3(1	Filssp sxp	≥ 28"					-
					==					

Description	Initial	Repair System	Other Factors (.1946):
	System		Site Classification (.1948):
Available Space (.1945)	-		Evaluated By: M NEHS
System Type(s)			Others Present:
Site LTAR	. 3	.3	

COMMENTS: ____

LANDSCAPE POSITIONS	<u>GROUP</u>	TEXTURES	. <u>1955 LTAR</u>	CONSISTENCE MOIST	WET
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE	I	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY
FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE	II	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC
CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	Ш	SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3		SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC

STRUCTURE SG-SINGLE GRAIN M- MASSIVE

CR-CRUMB GR-GRANULAR

SBK-SUBANGULAR BLOCKY ABK-ANGULAR BLOCKY

PL-PLATY

MINERALOGY SLIGHTLY EXPANSIVE

SIC-SILTY CLAY 0.4 - 0.1

EXPANSIVE

C-CLAY SC-SANDY CLAY

IV

