

April 3rd, 2024

Marilyn Langdon  
3149 Langdon Rd  
Angier, NC 27501

**RE: Existing Tank Application # BRES2403-0001**

To whom it may concern

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

\_\_\_ 1. Uncover outlet lid on septic tank fully and break seal, uncover D-Box. (\$25.00 fee incurred).

\_\_\_ 2. Have system pumped out

\_\_\_ 3. Need site plan

**X 4. Other – Site Plan is not correct based on field evaluation. Need survey map submitted to central permitting with property line measurements and correct house setbacks from property line. Need survey irons uncovered and demonstrated. Wrong lid uncovered on septic tank, also need seal broken free and a handle to lift the lid. Property lines must be flagged every 50'. Septic tank displays as 7' from front right house corner, not 35' as stated on site plan.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7523 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz, R.E.H.S.  
Environmental Health Specialist  
Harnett County Department of Public Health

RL/kh  
Copy - Central Permitting