

Harnett County Environmental Health

EXISTING SYSTEM APPROVAL

Existing System Approval

Site modification (e.g., storage shed) or footprint addition with no DDF or wastewater strength increase

Reconnection when the proposed facility is in the same footprint as existing/previous facility

Construction Authorization/Notice of Intent to Construct

[issued for reconnection when the proposed facility is not in the same footprint as existing/previous facility pursuant to Session Law 2023-77, Section 5.(c)]

[certified inspectors are not authorized to approve reconnections outside of footprint pursuant to Session Law 2023-77, Section 5.(c)]

Applicant: Trey Skandier

Mailing Address: 65 Big J St.

City: Erwin

State: NC Zip: 28339

Phone #: 919-606-9529

Email: tskandier@gmail.com

Owner: Same as applicant

Mailing Address: _____

City: _____

State: _____ Zip: _____

Phone #: _____

Email: _____

PIN/Lot Identifier: 0587-97-8900.000

Property Location/Address: 65 BIG J ST ERWIN, NC 28339

Facility Type: House/Modular Mobile/Manufactured Home Business Other: _____

Operation Permit/ATO #: SFD2012-0015 Design Daily Flow: 360 GPD

Number of Bedrooms: 3 Max # Occupants: 6 Other: _____

Wastewater Strength: Domestic High Strength Industrial Process Wastewater

Water Supply: Private well Public well Shared well Municipal Supply Spring Other: _____

Proposed Property Improvement: Adding a Bathroom in Existing Workshop/Office Affidavit Permitted 12' x 32' Shed. Hooking up to Existing SFD's Septic System.

All the following must be checked for approval:


No current or past uncorrected malfunction of the system as described in 15A NCAC 18E .1303(a)(2)

DDF and wastewater strength for the proposed facility or site modification do not exceed that of the existing system

Proposed facility or site modification meets the setbacks in Section .0600 of 15A NCAC 18E

Approval Conditions: During Bathroom Installation Avoid Driving on Septic Field.

Inspector's Printed Name: Ren Levocz Inspector Certification #: 3345

Inspector's Signature:  Date: 12-11-24

The existing system approval expires one year after the date of issuance.
****See attached site sketch****

EXISTING SYSTEM APPROVAL SITE SKETCH

Operation Permit/ATO #: SFD2012-0015


PIN/Lot Identifier: 0587-97-8900.000 Lot 4

Owner: Trey Skandier

Property Location/Address: 65 BIG J ST ERWIN, NC 28339

Op issued 11-18-2021

updated on 12-11-24



**Include the existing and proposed structures and applicable setbacks.*