INSULSTARLIGHT
HIGH PERFORMANCE OPEN-CELL SPF

12-008 Insulation Certification Form

Open Cell Spray-in-Place Polyurethane Foam Insulation System

Date Installation completed: July 9, 2025

Application Project Building Address: 681 Griffin Rd

City/State/Zip Lillington, NC 27546

Application Contractor: Energy Saving Insulation LLC
(Company Name)
Address: 1220 Cotten Farm Dr

City/State/Zip Fuquay - Varina, NC 27526 Phone # (919) 798-9906

List Values in the areas insulated -

Exterior Stud Wall: Average thickness 5” R-Value R19

Ceiling insulation: Average thickness _____ R-Value _____

Roof Deck insulation: Average thickness 10” R-Value R38

Crawl Space/Basement: Average thickness _____ R-Value _____

Special Areas insulated: _____

_____

I (print name) Energy Saving Insulaiton LLC as an Independent contractor, certify that the 12-008 Insulation installed on this project was applied in accordance with the NCFI recommendations and specifications as stated on the product data sheet and the 12-008 Application Specifications in the amount as indicated on this certification.

Oscar Contreras (signed) Date July 9, 2025

12-008 Spray Polyurethane Foam Insulation System R-Value Chart

Thickness	R-value		Thickness	R-Value
1”	3.7		8”	31
3.5”	13		11”	42
5.5”	21		14”	54

NCFI POLYURETHANES

12-008 is a product of Barnhardt MFG Co d/b/a NCFI Polyurethanes - Mount Airy, NC 27030

092019