



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

6/26/2025

SUBJECT: **BRES2403-0021**  
**BUILDING RESIDENTIAL**

To: NUNEZ GASPER

Here are the results of all Inspections located at **1398 NC 55 E:**

Inspection Type: ADDRESS  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: GIS Bucket  
Result:  
Remarks:  
Notes:

Inspection Type: FINAL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: MONO SLAB  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: SLAB  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: ROUGH IN  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: FOOTING  
Scheduled Date/Time: 3/20/2025  
Completed Date/Time: 3/20/2025  
Inspector: Daniel L Floyd  
Result: APPROVED  
Remarks:  
Notes: Customer is requesting morning, so they can pour before the rain

Inspection Type: FOUNDATION  
Scheduled Date/Time: 4/9/2025  
Completed Date/Time: 4/9/2025  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: ROUGH IN  
Scheduled Date/Time: 6/26/2025  
Completed Date/Time: 6/26/2025  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks:  
Notes: Need rafter ties on 4 foot centers in garage cannot just tie back to third joist