



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

5/16/2024

**SUBJECT: BRES2403-0048**  
**BUILDING RESIDENTIAL**

To: Anthony & Sylvan Pools North Carolina LLC

Here are the results of all Inspections located at **3610 KIPLING RD:**

Inspection Type: FINAL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: ZONING  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Planning Bucket  
Result:  
Remarks:  
Notes:

Inspection Type: BONDING  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: ELECTRICAL UNDERGROUND  
Scheduled Date/Time: 5/9/2024  
Completed Date/Time: 5/9/2024  
Inspector: Justin Ryan McLeod  
Result: APPROVED  
Remarks:  
Notes:





**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: BONDING

Scheduled Date/Time: 5/9/2024

Completed Date/Time: 5/9/2024

Inspector: Justin Ryan McLeod

Result: DISAPPROVED

Remarks:

Notes:

This was a partial inspection, this was to see the 4 points of connection to the rebar in pool and the bond wire in ditch from pump area to pool. This was good. Will need to see completed bonding when ready.