



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

8/23/2024

**SUBJECT: BRES2403-0052  
BUILDING RESIDENTIAL**

To: True Homes LLC

Here are the results of all Inspections located at **128 CAMEL CRAZIES PL:**

Inspection Type: DAMP PROOFING  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: FOOTING  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: FOUNDATION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: OPEN FLOOR  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: TAX INSPECTION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Tax Inspection  
Result:  
Remarks:  
Notes:

Inspection Type: FOUNDATION SURVEY  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: CP Bucket  
Result:  
Remarks: NEEDED  
Notes:

Inspection Type: SLAB  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: UNDER SLAB TRADES  
Scheduled Date/Time: 5/1/2024  
Completed Date/Time: 5/1/2024  
Inspector: Deen Taylor  
Result: APPROVED  
Remarks:  
Notes: plumbing and elect underground

Inspection Type: MONO SLAB  
Scheduled Date/Time: 5/7/2024  
Completed Date/Time: 5/7/2024  
Inspector: Deen Taylor  
Result: APPROVED  
Remarks:  
Notes:





**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: ADDRESS  
Scheduled Date/Time: 5/7/2024  
Completed Date/Time: 5/7/2024  
Inspector: GIS Bucket  
Result: APPROVED  
Remarks:  
Notes: 128 CAMEL CRAZIES LILLINGTON 27546.

Inspection Type: WATER CONNECTION  
Scheduled Date/Time: 5/9/2024  
Completed Date/Time: 5/9/2024  
Inspector: Deen Taylor  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: SEWER CONNECTION  
Scheduled Date/Time: 5/9/2024  
Completed Date/Time: 5/9/2024  
Inspector: Deen Taylor  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: T-POLE  
Scheduled Date/Time: 5/14/2024  
Completed Date/Time: 5/14/2024  
Inspector: Deen Taylor  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: ROUGH IN  
Scheduled Date/Time: 7/3/2024  
Completed Date/Time: 7/3/2024  
Inspector: Daniel L Floyd  
Result: DISAPPROVED  
Remarks:  
Notes: 1. Anchor interior load bearing wall under the stairs 2. Draft stop every 10ft in the wood studs 3. Studs are over 24" oc at the chase in the master bedroom



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: INSULATION

Scheduled Date/Time: 7/9/2024

Completed Date/Time: 7/9/2024

Inspector: Deen Taylor

Result: APPROVED

Remarks:

Notes:

Inspection Type: ROUGH IN REINSPECT

Scheduled Date/Time: 7/9/2024

Completed Date/Time: 7/9/2024

Inspector: Deen Taylor

Result: APPROVED

Remarks:

Notes:

Inspection Type: TEMP POWER CERTIFICATION

Scheduled Date/Time: 8/14/2024

Completed Date/Time: 8/14/2024

Inspector: Deen Taylor

Result: APPROVED

Remarks:

Notes:

Inspection Type: TOWNHOUSE FINAL\*\*

Scheduled Date/Time: 8/23/2024

Completed Date/Time: 8/23/2024

Inspector: Deen Taylor

Result: APPROVED

Remarks:

Notes: