

Howerton Services, PLLC
License # P-1716
3513 Cathedral Bell Road
Raleigh, NC 27614
(919) 270-3460

April 22, 2024

Subject: 3418 Matthews Mill Pond Road
Angier, NC 27501
Pole Barn Framing Modification Letter
Harnett County Permit #: BRES2403-007

Based on the request of the Contractor, the Pole Barn Post footings will be modified. My assessment and recommendations are as follows:

- The Contractor would like to use post brackets on the 6x6 treated posts in lieu of embedding the 6x6 posts into the concrete footings. The Contractor will use SWP66 Sturdi-Wall Anchor Brackets to attach the 6x6 posts to the concrete footings. The SWP66 brackets are an acceptable alternative.

The modified post attachments for the Pole Barn posts meet all the requirements of the 2018 North Carolina Building Code for Residences.

