



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

9/23/2024

SUBJECT: BRES2404-0029
BUILDING RESIDENTIAL

To: True Homes LLC

Here are the results of all Inspections located at **144 CAMEL CRAZIES PL:**

Inspection Type: ADDRESS
Scheduled Date/Time:
Completed Date/Time:
Inspector: GIS Bucket
Result:
Remarks:
Notes:

Inspection Type: DAMP PROOFING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: FOOTING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: FOUNDATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: OPEN FLOOR
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: T-POLE
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: TAX INSPECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Tax Inspection
Result:
Remarks:
Notes:

Inspection Type: WATER CONNECTION
Scheduled Date/Time: 5/21/2024
Completed Date/Time: 5/21/2024
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: UNDER SLAB TRADES
Scheduled Date/Time: 5/21/2024
Completed Date/Time: 5/21/2024
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:

Inspection Type: SEWER CONNECTION
Scheduled Date/Time: 5/21/2024
Completed Date/Time: 5/21/2024
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:

Inspection Type: MONO SLAB
Scheduled Date/Time: 5/28/2024
Completed Date/Time: 5/28/2024
Inspector: Daniel L Floyd
Result: APPROVED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 8/1/2024
Completed Date/Time: 8/1/2024
Inspector: Scott Guy
Result: APPROVED
Remarks:
Notes: Inspector DT changed the inspection assignment from DT to TSG

Inspection Type: FOUNDATION SURVEY
Scheduled Date/Time: 8/2/2024
Completed Date/Time: 8/2/2024
Inspector: CP Bucket
Result: APPROVED
Remarks: NEEDED
Notes:





Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: INSULATION
Scheduled Date/Time: 8/5/2024
Completed Date/Time: 8/5/2024
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time: 9/10/2024
Completed Date/Time: 9/10/2024
Inspector: Daniel L Floyd
Result: APPROVED
Remarks:
Notes:

Inspection Type: TOWNHOUSE FINAL **
Scheduled Date/Time: 9/20/2024
Completed Date/Time: 9/20/2024
Inspector: Scott Guy
Result: DISAPPROVED
Remarks:
Notes: 1/ install code compliant drain clean out cap and screw in closet for drain system 2/ secure water heater PRV drain pipe.

Inspection Type: TOWNHOUSE FINAL
Scheduled Date/Time: 9/24/2024
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

