



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

9/23/2024

SUBJECT: BRES2404-0032
BUILDING RESIDENTIAL

To: True Homes LLC

Here are the results of all Inspections located at **140 CAMEL CRAZIES PL:**

Inspection Type: ADDRESS
Scheduled Date/Time:
Completed Date/Time:
Inspector: GIS Bucket
Result:
Remarks:
Notes:

Inspection Type: DAMP PROOFING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: FOOTING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: FOUNDATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: OPEN FLOOR
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: TAX INSPECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Tax Inspection
Result:
Remarks:
Notes:

Inspection Type: WATER CONNECTION
Scheduled Date/Time: 5/21/2024
Completed Date/Time: 5/21/2024
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:

Inspection Type: UNDER SLAB TRADES
Scheduled Date/Time: 5/21/2024
Completed Date/Time: 5/21/2024
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: SEWER CONNECTION

Scheduled Date/Time: 5/21/2024

Completed Date/Time: 5/21/2024

Inspector: Deen Taylor

Result: APPROVED

Remarks:

Notes:

Inspection Type: T-POLE

Scheduled Date/Time: 5/24/2024

Completed Date/Time: 5/24/2024

Inspector: Brad Sutton

Result: APPROVED

Remarks:

Notes:

Inspection Type: MONO SLAB

Scheduled Date/Time: 5/28/2024

Completed Date/Time: 5/28/2024

Inspector: Daniel L Floyd

Result: APPROVED

Remarks:

Notes:

Inspection Type: ROUGH IN

Scheduled Date/Time: 8/5/2024

Completed Date/Time: 8/5/2024

Inspector: Deen Taylor

Result: APPROVED

Remarks:

Notes:

Inspection Type: FOUNDATION SURVEY

Scheduled Date/Time: 8/6/2024

Completed Date/Time: 8/6/2024

Inspector: CP Bucket

Result: APPROVED

Remarks:

NEEDED

Notes:



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: INSULATION
Scheduled Date/Time: 8/7/2024
Completed Date/Time: 8/7/2024
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time: 9/10/2024
Completed Date/Time: 9/10/2024
Inspector: Daniel L Floyd
Result: APPROVED
Remarks:
Notes:

Inspection Type: TOWNHOUSE FINAL **
Scheduled Date/Time: 9/20/2024
Completed Date/Time: 9/20/2024
Inspector: Scott Guy
Result: DISAPPROVED
Remarks:
Notes: 1/ install code compliant drain clean out cap and screw in closet for drain system 2/ secure water heater PRV drain pipe.

Inspection Type: TOWNHOUSE FINAL
Scheduled Date/Time: 9/24/2024
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

