

May 6th, 2024

Cavco Homes- Brandon Johnson
413 E. Jackson Blvd
Erwin, Nc 28339

RE: Existing Tank Application #BRES2404-0059

To whom it may concern

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank fully and break seal, uncover D-Box. (\$25.00 fee incurred).
- 2. Have system pumped out
- 3. Need site plan
- 4. Other – Will need septic contractor to locate and demonstrate septic lines start to end. Will require pits to see if there is any usable soil to determine if expansion is possible. The tax records do no indicate the previous bedroom count that the existing system was designed for. Environmental Health believes that the existing system was permitted for 2 bedroom,**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

RL/kh
Copy - Central Permitting