



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

8/26/2024

SUBJECT: BRES2405-0047
BUILDING RESIDENTIAL

To: CHANCE-MCNEILL TERESA

Here are the results of all Inspections located at **330 GREEN SPRING DR:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: James T Hall
Result:
Remarks:
Notes:

Inspection Type: INSULATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: James T Hall
Result:
Remarks:
Notes:

Inspection Type: MONO SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: James T Hall
Result:
Remarks:
Notes:

Inspection Type: SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: James T Hall
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: UNDER SLAB TRADES
Scheduled Date/Time:
Completed Date/Time:
Inspector: James T Hall
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN REINSPECT
Scheduled Date/Time:
Completed Date/Time:
Inspector: James T Hall
Result:
Remarks:
Notes:

Inspection Type: FOOTING
Scheduled Date/Time: 6/21/2024
Completed Date/Time: 6/21/2024
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:

Inspection Type: FOUNDATION
Scheduled Date/Time: 7/1/2024
Completed Date/Time: 7/1/2024
Inspector: James T Hall
Result: APPROVED
Remarks:
Notes:

Inspection Type: OPEN FLOOR
Scheduled Date/Time: 7/10/2024
Completed Date/Time: 7/10/2024
Inspector: James T Hall
Result: APPROVED
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: ROUGH IN

Scheduled Date/Time: 8/26/2024

Completed Date/Time: 8/26/2024

Inspector: John B Kokoszka

Result: DISAPPROVED

Remarks:

Notes:

Need to fire stops lines and thermostat wire Missing baffles Need correct header for rear door
Rafter need to bear solid on ridge beam Missing attic access for unit Flashing on window and
doors correct Need to tape house wrap joists Missing outlets outside DWV low water test