

Permit Inspections Harnett County

Permit Number: BRES2405-0055 Description: 14x76

Applied: 5/22/2024 Approved: 9/19/2024 Site Address: 49 BRITTON LOOP

Issued: **7/2/2024** Finaled: **9/24/2024** City, State Zip Code: **CAMERON, NC 28326**

Status: FINALED Applicant: SIX DEGREES INVESTMENT VENTURES LLC

Parent Permit: Owner: SIX DEGREES INVESTMENT VENTURES LLC

Parent Project: Contractor: A PLUS CONSTRUCTION

Details:

LIST OF INSPECTIONS									
SEQ ID	SCHEDULED DATE	COMPLETED DATE	ТҮРЕ	INSPECTOR	RESULT	REMARKS			
	7/17/2024	7/17/2024	MH FOUND/MARRIAG E WALL	Steven Gazlay	APPROVED				
Notes:									
	8/5/2024	8/5/2024	ADDRESS	GIS Bucket	APPROVED				
Notes:									
49 Britton Loop, Cameron, NC 28326									
	8/5/2024	8/5/2024 11:00 AM	ZONING	Kyle Holder	APPROVED	eTRAKiT Inspection Request			
Notes:									
8/2/2024 1:14 PM Ruth Norton									
Contact Name: Ruth Norton Site Address: 49 BRITTON LOOP Phone: 9197741125 e-Mail: ruth.norton@claytonhomes.com									
	8/22/2024	8/22/2024	FINAL**	James T Hall	DISAPPROVED	eTRAKiT Inspection Request			

Notes:

8/21/2024 2:47 PM Ruth Norton

lock box 1034

Contact Name: Ruth Norton
Site Address: 49 BRITTON LOOP

Phone: 9197741125

e-Mail: ruth.norton@claytonhomes.com

Not ready for final inspection DWV test still on and sewer line not connected to anything outside homeNeed permit for back deck and it needs to meet the code Water line test still on and not connected to a water source



Permit Inspections Harnett County

	9/24/2024 9/24/2024	FINAL**	Ricardo D Honrada	APPROVED	eTRAKiT Inspection Request
--	---------------------	---------	----------------------	----------	----------------------------

Notes:

9/3/2024 12:15 PM Ruth Norton

lock box 1034

Contact Name: Ruth Norton Site Address: 49 BRITTON LOOP

Phone: 9197741125

e-Mail: ruth.norton@claytonhomes.com

Need to apply permits for the deck.

