



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

10/15/2024

**SUBJECT: BRES2405-0069**  
**BUILDING RESIDENTIAL**

To: Bruce Steger

Here are the results of all Inspections located at **524 LONGLEAF DR:**

Inspection Type: ADDRESS  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: GIS Bucket  
Result:  
Remarks:  
Notes:

Inspection Type: SEWER CONNECTION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: James T Hall  
Result:  
Remarks:  
Notes:

Inspection Type: WATER CONNECTION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: James T Hall  
Result:  
Remarks:  
Notes:

Inspection Type: ZONING  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Planning Bucket  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: ENVIR OPERATIONS PERMIT  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: EH Bucket  
Result:  
Remarks:  
Notes:

Inspection Type: MFH FINAL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: James T Hall  
Result:  
Remarks:  
Notes:

Inspection Type: MH FOUND/MARRIAGE WALL  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: James T Hall  
Result:  
Remarks: eTRAKiT Inspection Request  
Notes:

Inspection Type: FOOTING  
Scheduled Date/Time: 7/30/2024  
Completed Date/Time: 7/30/2024  
Inspector: John B Kokoszka  
Result: DISAPPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: this is required

7/29/2024 9:43 AM MARTY WRIGHT HOME SALES KNIGHT  
PIER/BRICK FOOTING  
Contact Name: MARTY WRIGHT HOME SALES KNIGHT  
Site Address: 524 LONGLEAF DR  
Phone: 9105639933  
e-Mail: carriesknight@gmail.com

Inspector JTH changed the inspection assignment from JTH to JBK  
Road blocked by power company



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: FOOTING  
Scheduled Date/Time: 8/5/2024  
Completed Date/Time: 8/5/2024  
Inspector: James T Hall  
Result: DISAPPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 7/31/2024 2:27 PM MARTY WRIGHT HOME SALES KNIGHT

Contact Name: MARTY WRIGHT HOME SALES KNIGHT  
Site Address: 524 LONGLEAF DR  
Phone: 9105639933  
e-Mail: carriesknight@gmail.com

8/2/2024 11:09 AM MARTY WRIGHT HOME SALES KNIGHT

Contact Name: MARTY WRIGHT HOME SALES KNIGHT  
Site Address: 524 LONGLEAF DR  
Phone: 9105639933  
e-Mail: carriesknight@gmail.com

No plans in permit box  
Need to clean loose dirt from bottom of footings  
Need to mark depth of footings  
Missing step downs in footings

Inspection Type: FOOTING  
Scheduled Date/Time: 9/3/2024  
Completed Date/Time: 9/3/2024  
Inspector: Daniel L Floyd  
Result: DISAPPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 8/29/2024 12:17 PM MARTY WRIGHT HOME SALES KNIGHT

Contact Name: MARTY WRIGHT HOME SALES KNIGHT  
Site Address: 524 LONGLEAF DR  
Phone: 9105639933  
e-Mail: carriesknight@gmail.com

Need plans Full of water



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: FOOTING  
Scheduled Date/Time: 9/6/2024  
Completed Date/Time: 9/6/2024  
Inspector: John B Kokoszka  
Result: DISAPPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 9/5/2024 2:00 PM MARTY WRIGHT HOME SALES KNIGHT

Contact Name: MARTY WRIGHT HOME SALES KNIGHT  
Site Address: 524 LONGLEAF DR  
Phone: 9105639933  
e-Mail: carriesknight@gmail.com

Footing has water in them. Need to clean out and has crush and run in the footing. Need engineer letter

Inspection Type: FOOTING  
Scheduled Date/Time: 10/11/2024  
Completed Date/Time: 10/11/2024  
Inspector: Daniel L Floyd  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 10/10/2024 11:20 AM MARTY WRIGHT HOME SALES KNIGHT  
LB 2016 OR 0913 ENGINEER LETTER  
Contact Name: MARTY WRIGHT HOME SALES KNIGHT  
Site Address: 524 LONGLEAF DR  
Phone: 9105639933  
e-Mail: carriesknight@gmail.com

3rd party

Inspection Type: MH FOUND/MARRIAGE WALL  
Scheduled Date/Time: 10/14/2024  
Completed Date/Time: 10/14/2024  
Inspector: James T Hall  
Result: DISAPPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 10/11/2024 2:04 PM MARTY WRIGHT HOME SALES KNIGHT  
LB 2016 OR 0913  
Contact Name: MARTY WRIGHT HOME SALES KNIGHT  
Site Address: 524 LONGLEAF DR  
Phone: 9105639933  
e-Mail: carriesknight@gmail.com



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: Not ready for inspection plumber and electrician still working no inspection done

Scheduled Date/Time:

Inspection Type: MH FOUND/MARRIAGE WALL

Scheduled Date/Time: 10/15/2024

Completed Date/Time: 10/15/2024

Inspector: James T Hall

Result: DISAPPROVED

Remarks: eTRAKiT Inspection Request

Notes: 10/14/2024 1:39 PM MARTY WRIGHT HOME SALES KNIGHT  
LB 2016 OR 0913 PLEASE MARK ON INSPECTION IF MATE LINE OK TO COVER  
Contact Name: MARTY WRIGHT HOME SALES KNIGHT  
Site Address: 524 LONGLEAF DR  
Phone: 9105639933  
e-Mail: carriesknight@gmail.com

Sleeve plumbing pipe where goes through curtain wall Seal hole under back left corner at tub  
drop They set up manual for Home