

## Harnett County Environmental Health

### EXISTING SYSTEM APPROVAL

Issued by:     Local Health Department     AOWE     Certified Inspector

Existing System Approval

Site modification (e.g., storage shed) or footprint addition with no DDF or wastewater strength increase

Reconnection when the proposed facility is in the same footprint as existing/previous facility

Construction Authorization/Notice of Intent to Construct

[issued for reconnection when the proposed facility is not in the same footprint as existing/previous facility pursuant to Session Law 2023-77, Section 5.(c)]

[certified inspectors are not authorized to approve reconnections outside of footprint pursuant to Session Law 2023-77, Section 5.(c)]

Applicant: Strange Liz

Mailing Address: 128 US Hwy 70 E Unit B

City: Garner

State: NC                      Zip: 27529

Phone #: 919-669-9713

Email: elizabeth@capitalpools.com

Owner: Brian Schilling

Mailing Address: 106 NORRIS FARM DR ANGIER, NC 27501

City: Angier

State: NC                      Zip: 27501

Phone #: N/A

Email: N/A

PIN/Lot Identifier: 0663-71-9816.000 Lot 19

Property Location/Address: 106 NORRIS FARM DR ANGIER, NC 27501

Facility Type:  House/Modular     Mobile/Manufactured Home     Business     Other: \_\_\_\_\_

Operation Permit/ATO #: SFD 2001-0031                      Design Daily Flow: 360                      GPD

Number of Bedrooms: 3                      Max # Occupants: 6                      Other: \_\_\_\_\_

Wastewater Strength:  Domestic     High Strength     Industrial Process Wastewater

Water Supply:  Private well     Public well     Shared well     Municipal Supply     Spring     Other: \_\_\_\_\_

Proposed Property Improvement: 20' x 40' In ground Pool

All of the following must be checked for approval:

**\*For Reconnections:**


- Site complies with its Operation Permit or the wastewater system was in use prior to July 1, 1977
- No current or past uncorrected malfunction of the system as described in 15A NCAC 18E .1303(a)(2)
- DDF and wastewater strength for the proposed facility do not exceed that of the existing system
- Facility meets the setbacks in Section .0600 of 15A NCAC 18E
- Existing system is being operated and maintained in accordance with Section .1300 of 15A NCAC 18E and permit conditions.

**\*For Site Modifications or Footprint Expansions:**

- Proposed structure meets the setbacks in Section .0600 of 15A NCAC 18E

Approval Conditions: During Pool Install (Must Keep Pool 15' off any part of septic system)

Inspector's Printed Name: Ren Levocz                      Inspector Certification #: 3345

Inspector's Signature:                       Date: 7-19-24

**\*See attached site sketch\***


# EXISTING SYSTEM APPROVAL SITE SKETCH

Operation Permit/ATO #: SFD 2001-0031

PIN/Lot Identifier: 0663-71-9816.000 Lot 19

Owner: Brian Schilling

Property Location/Address: 106 NORRIS FARM DR ANGIER, NC 27501



*\*Include the existing and proposed structures and applicable setbacks.*