

APPENDIX G

DESIGN PROFESSIONAL INSPECTION FORM

RECORD OF THE INSPECTION OF A **COMPONENT OR ELEMENT** BY A NC LICENSED ARCHITECT OR ENGINEER

Project Information:

Residential Single-Family Project: Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	Commercial Project: Y <input type="checkbox"/> N <input type="checkbox"/>
Code Enforcement Project No:	Permit No:
Project Name: 24 Village Way	Owner:
Project Address: 26 Village Way, Lillington, NC	Suite No:
Date Inspected: 6/27/2024	Contractor Name: Tim Goodwin
Component Inspected: footing excavation for patio stem wall	

Responsible Licensed NC Architect or NC Engineer

Name:	Randy Wise, PE	
Firm Name:	Wise Engineering	
Phone Numbers:	Office: 919-754-7907	Mobile: 919-754-7907
Email Address:	randy@wise-engineer.com	
Mailing Address:	3915 Old Fairground Rd., Angier, NC 27501	

APPLICABLE CODE:

2018 NCRC

2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code

Describe Element/Component/Type of Inspection: *

Spread footing excavation sufficient to support 8" Stem wall. Soil bearing exceeds 2000 PSF capacity. Footing and Stem Wall will adequately support loading of the covered patio as required.

*(subgrade form/letter may also be required)

Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per G.S. 160D-11-6 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced code. Attach any additional documents if needed.



 Licensed Architect or Engineer



Inspection Department disclaimer:

Upon the receipt of a signed written document as required by G.S. 160D-11-6, Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.

Effective January 1st, 2021