

APPENDIX G DESIGN PROFESSIONAL INSPECTION FORM

RECORD OF THE INSPECTION OF A COMPONENT OR ELEMENT BY A NC LICENSED ARCHITECT OR ENGINEER

Project Information:

Residential Single-Family Project: Y N	Commercial Project: Y N
Code Enforcement Project No:	Permit No:
Project Name: RICKY ARCHER	Owner:
Project Address: 593 CHEROKEE LANE LILLINGSTON AL	Suite No:
Date Inspected: 02/19/2024	Contractor Name:
Component Inspected: SOIL BEARING	

Responsible Licensed NC Architect or NC Engineer

Name:	WAYNE R. DASHIELD PE
Firm Name:	WAYNE R. DASHIELD PE
Phone Numbers:	Office: 919-934-0961 Mobile: -
Email Address:	WRDASHIELD PE @ GMAIL.COM
Mailing Address:	421-B S. BRICHTLEAF BLVD, SMITHFIELD, NC

APPLICABLE CODE:

2019 STATE REG FOR MANUFACTURED HOMES


Describe Element/Component/Type of Inspection: *

SOIL BEARING

Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per G.S. 160D-11-6 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced code. Attach any additional documents if needed.

Wayne R. Dashield **02/19/24**
Licensed Architect or Engineer



Inspection Department disclaimer:

Upon the receipt of a signed written document as required under subsection (a) of G.S. 160D-11-1, Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.