

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

September 4th, 2024

Kaleb & Heather Burrell
180 Cypress Church Rd
Cameron, NC 28326

RE: Existing Tank Application #BRES2406-0045

To whom it may concern

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover outlet lid on septic tank fully and break seal, replace sanitary Tee if it's bad. Locate and uncover D-BOX. (\$25.00 fee incurred).

2. Have system pumped out

3. Need site plan

4. Other – Septic system is designed for 4 bedroom. You will need to stay with 4 bedroom or apply for an expansion at Central Permitting.

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7525 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

MO/kh
Copy - Central Permitting