

APPENDIX G

DESIGN PROFESSIONAL INSPECTION FORM

RECORD OF THE INSPECTION OF A COMPONENT OR ELEMENT BY A NC LICENSED ARCHITECT OR ENGINEER

Project Information:

Residential Single-Family Project: <input checked="" type="radio"/> Y <input type="radio"/> N	Commercial Project: Y <input checked="" type="radio"/> N
Code Enforcement Project No:	Permit No: BRES 2407-0007
Project Name: 124 Harborview foundation repair	Owner: Karen Lollis
Project Address: 124 Harborview	Suite No:
Date Inspected: 8/8/2024	Contractor Name: Tarheel Basement Systems
Component Inspected: Helical piers and Intellijacks	

Responsible Licensed NC Architect or NC Engineer

Name:	Jacob Bullinger
Firm Name:	Scapular Engineering Firm
Phone Numbers:	Office: (573) 275-7647 Mobile: (573) 275-7647
Email Address:	jacob.bullinger@scapularengineering.com
Mailing Address:	23576 State Route J, St. Mary, MO 63673

APPLICABLE CODE:

2018 NCRC

2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code

Describe Element/Component/Type of Inspection: *

Helical piers have been installed per engineered specifications and designs.

Intellijacks and attachments have been installed per engineered specifications and designs.


Footings are to engineer specifications and at a pressure suitable to pour/build.

*(subgrade form/letter may also be required)


Soil bearing reflects 2,000 PSI.

Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per G.S. 160D-11-6 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced code. Attach any additional documents if needed.



 Licensed Architect or Engineer



Inspection Department disclaimer:

Upon the receipt of a signed written document as required under subsection (a) of G.S. 160D-11-1, Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.