

July 19, 2024

ph: 910-893-7550

fax: 910-893-9429

Har-Law Realty Corp of NC
56 E Williams Street
Angier NC 27518

RE: Application # BRES2407-0009

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

2. Have system pumped out

3. Replace Sanitary T

4. **Other – Site was originally designed for a 3-bedroom. (The proposed 4-bedroom SW is not approved). Must be a 3-bedroom. The original DW dimensions were 24’x58’ (the proposed SW is 14’x76’). Septic Tank must be uncovered (may be asked to have septic contractor locate and demonstrate drain lines if further inspection is needed.)**

Your application will be put on hold until the selected items above have been addressed.

When completed, **call (910) 893-7547 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

RL/slc

Copy - Central Permitting