



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

10/25/2024

SUBJECT: BRES2407-0016
BUILDING RESIDENTIAL

To: W.T.F. Construction

Here are the results of all Inspections located at **114 LAHINCH DR:**

Inspection Type: FOOTING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: UNDER SLAB TRADES
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: OPEN FLOOR
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:





Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: MONO SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: FOUNDATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN REINSPECT
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 10/9/2024
Completed Date/Time: 10/9/2024
Inspector: Deen Taylor
Result: DISAPPROVED
Remarks:
Notes: Plans call for 16 x 16 footers under posts, none there, footing inspection never scheduled or approved. Mechanically fasten posts to bands under rafters.

Inspection Type: FINAL**
Scheduled Date/Time: 10/25/2024
Completed Date/Time: 10/25/2024
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks:
Notes:

