

HANNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH SECTION

No 13069

# OPERATIONS PERMIT

Name: (owner) T.C. Miller  New Installation  Septic Tank  
Property Location: SR# 1708  Repairs  Nitrification Line  
Subdivision \_\_\_\_\_ Lot # \_\_\_\_\_  
TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
Contractor: C. Lee Godwin Registration # \_\_\_\_\_

Basement with Plumbing:  Garage:   
Water Supply:  Well  Public  Community  
Distance From Well: 50 min ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other \_\_\_\_\_

Size of tank: Septic Tank: Existing tank gallons Pump Tank: \_\_\_\_\_ gallons


Subsurface Drainage Field No. of ditches 2 exact length of each ditch 120 ft. width of ditches 3 ft. depth of ditches 18-20 in.

French Drain: \_\_\_\_\_ Linear feet

Date: 8/21/98

PERMIT NO. 15101

Inspected by: Bryan M. Swain  
Environmental Health Specialist



HARNETT COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT

No 15101

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) T.C. Miller

- checkbox New Installation, checkbox Septic Tank, checkbox Repairs, checkbox Nitrification Line

Property Location: SR# 1708

Subdivision \_\_\_\_\_ Lot # \_\_\_\_\_

Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 2 Lot Size: 1 acre

Basement with Plumbing: checkbox Garage: checkbox

Water Supply: checkbox Well, checkbox Public, checkbox Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: checkbox Conventional, checkbox Other

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field No. of ditches 2 exact length of each ditch 120 ft. width of ditches 3 ft. depth of ditches 18-20 in.

French Drain Required: \_\_\_\_\_ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 8-17-58

Signed: James E. Markant E.S. Environmental Health Specialist

