

Harnett County Department of Public Health

PERMIT # B-2407-0033

Operation Permit

New Installation Septic Tank Nitrification Line Repair Expansion

PROPERTY LOCATION: 4198 Darroch Rd (SR 1128)

Name: (owner) Weaver Homes

SUBDIVISION

LOT # 3

System Installer: Yellow Dog

Basement with plumbing: Garage Number of Bedrooms 3 (6 people)

Type of Water Supply: Community Public Well Distance from well _____ feet


System Type: Type III B

Types V and VI Systems expire in 5 years.

(In accordance with Table V a)

Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



PERMIT CONDITIONS:

I. Performance: System shall perform in accordance with Rule .1961.

II. Monitoring: As required by Rule .1961.

III. Maintenance: As required by Rule .1961. Other: _____

Subsurface system operator required? Yes No

If yes, see attached sheet for additional operation conditions, maintenance and reporting.

IV. Operation: _____

V. Other: _____

D-Box Pump Alarm H2OLine PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: Conventional Other 25% reduction in Q4

Subsurface No. of exact length Septic Tank: 1000 gallons Pump Tank: 1000 gallons

Drainage Field ditches 1 of each ditch 232 feet

French Drain Required: _____ Linear feet 3 feet 23 inches

Authorized State Agent _____

RCAS

Date 10/22/05