



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

7/14/2025

SUBJECT: **BRES2407-0034**  
**BUILDING RESIDENTIAL**

To: Rescue Construction Solution

Here are the results of all Inspections located at **121 STEWART FARM LN:**

Inspection Type: ADDRESS  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: GIS Bucket  
Result:  
Remarks:  
Notes:

Inspection Type: ROUGH IN  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks:  
Notes:

Inspection Type: SEWER CONNECTION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks:  
Notes:

Inspection Type: T-POLE  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: TEMP POWER CERTIFICATION

Scheduled Date/Time:

Completed Date/Time:

Inspector: Steven Gazlay

Result:

Remarks:

Notes:

Inspection Type: WATER CONNECTION

Scheduled Date/Time:

Completed Date/Time:

Inspector: Steven Gazlay

Result:

Remarks:

Notes:

Inspection Type: MODULAR FINAL\*\*

Scheduled Date/Time:

Completed Date/Time:

Inspector: Steven Gazlay

Result:

Remarks:

Notes:

Inspection Type: ZONING

Scheduled Date/Time:

Completed Date/Time:

Inspector: Planning Bucket

Result:

Remarks: Flood final Cert inspection

Notes:

Inspection Type: FOOTING

Scheduled Date/Time: 5/21/2025

Completed Date/Time: 5/21/2025

Inspector: James T Hall

Result: APPROVED

Remarks:

Notes:



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: FOUNDATION

Scheduled Date/Time: 6/17/2025

Completed Date/Time: 6/17/2025

Inspector: Deen Taylor

Result: DISAPPROVED

Remarks:

Notes: Top of footing must be exposed for foundation inspection to verify bed joint and projection.

Top of footing must be exposed for foundation inspection to verify bed joint and projection.

Inspection Type: FOUNDATION

Scheduled Date/Time: 6/24/2025

Completed Date/Time: 6/24/2025

Inspector: James T Hall

Result: DISAPPROVED

Remarks:

Notes: Uncover footings on foundation walls and piers inside and out for inspection

Inspection Type: FOUNDATION

Scheduled Date/Time: 6/26/2025

Completed Date/Time: 6/26/2025

Inspector: Ricardo D Honrada

Result: APPROVED

Remarks:

Notes:

Inspection Type: MARRIAGE WALL

Scheduled Date/Time: 7/11/2025

Completed Date/Time: 7/11/2025

Inspector: James T Hall

Result: APPROVED

Remarks:

Notes: