



Permit Inspections

Harnett County

Permit Number: **BRES2407-0034**

Description: **58.2x29.7 Off Frame**

Applied: **7/9/2024**

Approved: **9/16/2024**

Site Address: **121 STEWART FARM LN**

Issued: **9/19/2024**

Finalized:

City, State Zip Code: **SPRING LAKE, NC 28390**

Status: **ISSUED**

Applicant: **Rescue Construction Solution**

Parent Permit:

Owner: **DARRIGAN SHERRY STEWART**

Parent Project:

Contractor: **Rescue Construction Solution**

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			ADDRESS	GIS Bucket		
Notes:						
			MARRIAGE WALL	Steven Gazlay		
Notes:						
			ROUGH IN	Steven Gazlay		
Notes:						
			SEWER CONNECTION	Steven Gazlay		
Notes:						
			T-POLE	Steven Gazlay		
Notes:						
			TEMP POWER CERTIFICATION	Steven Gazlay		
Notes:						
			WATER CONNECTION	Steven Gazlay		
Notes:						
	5/21/2025	5/21/2025	FOOTING	James T Hall	APPROVED	
Notes:						
	6/17/2025	6/17/2025	FOUNDATION	Deen Taylor	DISAPPROVED	
Notes:						
Top of footing must be exposed for foundation inspection to verify bed joint and projection.						
Top of footing must be exposed for foundation inspection to verify bed joint and projection.						



Permit Inspections

Harnett County

	6/24/2025	6/24/2025	FOUNDATION	James T Hall	DISAPPROVED	
Notes: Uncover footings on foundation walls and piers inside and out for inspection						
	6/26/2025	6/26/2025	FOUNDATION	Ricardo D Honrada	APPROVED	
Notes:						
20			ZONING	Planning Bucket		Flood final Cert inspection
Notes:						
40			MODULAR FINAL**	Steven Gazlay		
Notes:						