



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

11/20/2024

**SUBJECT: BRES2407-0036**  
**BUILDING RESIDENTIAL**

To: Clayton Homes of Youngsville

Here are the results of all Inspections located at **365 BETTS RD:**

Inspection Type: ADDRESS  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: GIS Bucket  
Result:  
Remarks:  
Notes:

Inspection Type: MFH FINAL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: SEWER CONNECTION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: WATER CONNECTION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: ZONING  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Planning Bucket  
Result:  
Remarks:  
Notes:

Inspection Type: MH FOUND/MARRIAGE WALL  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: FOUNDATION  
Scheduled Date/Time: 11/14/2024  
Completed Date/Time: 11/14/2024  
Inspector: Justin Ryan McLeod  
Result: DISAPPROVED  
Remarks:  
Notes: Using a probe rod the projection seems short on the only side of the pier that is covered with dirt. The pier in question will be the center most pier. Uncover footing at this area to make sure there is 2" minimum projection. Footing not passed, could not locate letter.

Inspection Type: MH FOUND/MARRIAGE WALL  
Scheduled Date/Time: 11/14/2024  
Completed Date/Time: 11/14/2024  
Inspector: Justin Ryan McLeod  
Result: CANCELLED  
Remarks:  
Notes: This was scheduled but should be just foundation. Cancelled marriage wall and added foundation inspection

Inspection Type: FOOTING  
Scheduled Date/Time: 11/14/2024  
Completed Date/Time: 11/14/2024  
Inspector: Justin Ryan McLeod  
Result: DISAPPROVED  
Remarks:  
Notes: engineered letter attachments  
Do not see letter for footings





**Harnett County**  
420 Mckinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: FOUNDATION  
Scheduled Date/Time: 11/19/2024  
Completed Date/Time: 11/19/2024  
Inspector: Justin Ryan McLeod  
Result: APPROVED  
Remarks:  
Notes: Eng letter in attachments.  
Third party letter

Inspection Type: FOOTING  
Scheduled Date/Time: 11/19/2024  
Completed Date/Time: 11/19/2024  
Inspector: Justin Ryan McLeod  
Result: APPROVED  
Remarks:  
Notes: Eng letter in attachments.  
Third party