

# WRIGHT R ARCHER III ENGINEERING

8 Baytree Court Greensboro, NC 27455

November 11, 2024

W. Lawrence Terry  
2646 John Brewer Road  
Leasburg, NC 27281

Subject: Foundation Inspection For:

365 Betts Road  
Holly Springs, NC

I inspected the foundation excavation for the address above on October 29, 2024. I found the footing excavations have been properly dug on grade per required code, and meeting the requirements in bearing capacity, layout, depth and width. The footing excavations were free of loose material and organic material at the time of concrete placement.

This foundation as constructed will provide adequate support for the structure and meets or exceeds the manufactures requirements and my design criteria for wind zone 1 which includes Harnett County.

If you have any question or need additional information please contact me at 336-681-5912.

Sincerely,



Wright R. Archer III, P.E.  
Engineering Consultant



Harnett County Inspections Dept.

**DESIGN PROFESSIONAL INSPECTION FORM**

RECORD OF THE INSPECTION OF A COMPONENT OR ELEMENT BY A NC LICENSED ARCHITECT OR ENGINEER **Project**

**Information:**

Residential Single-Family Project: <b>Yes</b>	Commercial Project: Y N
Code Enforcement Project No:	Permit No: <b>BRES 2407-0036</b>
Project Name:	Owner:
Project Address: <b>365 Belts Road Holly Springs, NC</b>	Suite No:
Date Inspected: <b>October October 29, 2024</b>	Contractor Name:
Component Inspected: <b>Footing Excavations</b>	

**Responsible Licensed NC Architect or NC Engineer**

Name:	Wright R. Archer III, PE		
Firm Name:	Wright R. Archer III Engineering		
Phone Numbers:	Office:	Mobile:	336-681-5912
Email Address:	wrightarcheriii@gmail.com		
Mailing Address:	8 Baytree Court Greensboro, NC 27455		

**APPLICABLE CODE:**

2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code

Describe Element/Component/Type of Inspection: \*


**The Footing Excavatoins were free of loose and organic material at the time of concrete placement.**

\*(subgrade form/letter may also be required)

**Attestation/Signature:**

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per subsection (b2) of NC G.S. 153A352 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced Code. Attach any additional documents if needed.

*Wright R Archer III*  
 \_\_\_\_\_  
 Licensed Architect or Engineer



**Inspection Department disclaimer:**

Upon the receipt of a signed written document as required under subsection (a) of Article 160A-413.5., Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.