



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

10/9/2024

SUBJECT: **BRES2407-0066**
BUILDING RESIDENTIAL

To: BRYANT ADAM EUGENE

Here are the results of all Inspections located at **1604 BRICK MILL RD:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: FOOTING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: OPEN FLOOR
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN REINSPECT
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: ROUGH IN
Scheduled Date/Time: 10/9/2024
Completed Date/Time: 10/9/2024
Inspector: Steven Gazlay
Result: DISAPPROVED

Remarks:

Notes:

Footing inspection never approved, footings not constructed to code. Provide engineering for no rafter ties and ridge not sized as beam. Need code compliant method to attach headers and girders to posts. Remove osb to allow inspection of framing onto house.