



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

10/30/2025

SUBJECT: BRES2408-0006
BUILDING RESIDENTIAL

To: SRP CAMERON LLC

Here are the results of all Inspections located at **423 TED BROWN RD**:

Inspection Type: ADDRESS

Scheduled Date/Time:

Completed Date/Time:

Inspector: GIS Bucket

Result:

Remarks:

Notes:

Inspection Type: FINAL**

Scheduled Date/Time:

Completed Date/Time:

Inspector: Steven Gazlay

Result:

Remarks:

Notes:

Inspection Type: MH FOUND/MARRIAGE WALL

Scheduled Date/Time: 8/12/2025

Completed Date/Time: 8/12/2025

Inspector: Ricardo D Honrada

Result: DISAPPROVED

Remarks:

Notes: LOCK BOX 4648

Need house number.

Inspection Type: ENVIR OPERATIONS PERMIT

Scheduled Date/Time: 9/11/2025

Completed Date/Time: 9/11/2025

Inspector: Mark Osborne

Result: APPROVED

Remarks:

Notes:



Harnett County
420 Mckinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: MH FOUND/MARRIAGE WALL

Scheduled Date/Time: 10/13/2025

Completed Date/Time: 10/13/2025

Inspector: Ricardo D Honrada

Result: DISAPPROVED

Remarks:

Notes: LOCK BOX 4648

Need third party letter for over height piers. Two grounding rods and GEC and feeder ok. Marriage wall exterior and interior wall ok.

Inspection Type: WATER SERVICE INSPECTION

Scheduled Date/Time: 10/13/2025

Completed Date/Time: 10/13/2025

Inspector: Ricardo D Honrada

Result: APPROVED

Remarks:

Notes: Connected from existing service pipe.

Inspection Type: SEWER SERVICE INSPECTION

Scheduled Date/Time: 10/13/2025

Completed Date/Time: 10/13/2025

Inspector: Ricardo D Honrada

Result: APPROVED

Remarks:

Notes:

Inspection Type: MH FOUND/MARRIAGE WALL

Scheduled Date/Time: 10/28/2025

Completed Date/Time: 10/28/2025

Inspector: Ricardo D Honrada

Result: APPROVED

Remarks:

Notes: lock box 4610

Third party letter attached, over height piers.

Inspection Type: ZONING

Scheduled Date/Time: 10/29/2025

Completed Date/Time: 10/29/2025 12:00 PM

Inspector: Kyle Holder

Result: APPROVED

Remarks:

Notes: lock box is 4610



Harnett County
420 Mckinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL**

Scheduled Date/Time: 10/30/2025

Completed Date/Time: 10/30/2025

Inspector: Ricardo D Honrada

Result: DISAPPROVED

Remarks:

Notes: lock box is 4610

Screen door locked no access to lock box. Back door locked. Secure and support the whip connector for ac.